

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name: Purnea Division Name: P.H.Division, Purnea

Month: May-2023

Sl. No.	Block	Panchyat	Village/Habitation	Location of Source	Latitude		Longitude		Parameters														
					°N	Min.	Sec.	°E	Min.	Sec.	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F
1	Purnea East	Nagar Nigam Purnea	Madhopara	Sahara Advance World School					7.1	4	327	212	96	18	7.8	16	100	0.4	BDL	25	0.2	BDL	NEGATIVE
									6.5-8.5	5.0	-	500	300	75	30	250	200	1.0	BDL	200	1.0	0.01	NEGATIVE
									NR	10.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	NEGATIVE

Desirable Limit*

Permissible Limit* in absence of alternate source

[Signature]
27/05/23
Assistant Chemist
P.H. Division, Purnea

[Signature]
27/05/2023
Chemist
P.H. Div.
Purnea

[Signature]
27/5/23
A.E.
P.H. Sub Division, Purnea

[Signature]
27-06-23
Executive Engineer
P.H. Division, Purnea
Executive Engineer
P.H. Division, P.