

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name: Purnea			Division Name: P.H. Division Purnea						Month: May 2024																
Sl. No.	Block	Panchayat	Village/Habitation	Location of Source	Latitude			Longitude			Parameters														
					N	Min.	Sec.	E	Min.	Sec.	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli
1	Purnea East	Nagar Nigam Purnea	Mechopaira	Sahara Advance World School							7.1	4	327	212	96	18	7.8	16	100	0.4	BDL	25	0.2	BDL	NEGATIVE
Desirable Limit*											6.5-8.5	5.0	-	500	300	75	30	250	200	1.0	BDL	200	1.0	0.01	NEGATIVE
Permissible Limit* in absence of alternate source											NR	10.0	-	2000	500	200	100	1000	000	NR	NR	400	1.5	NR	NEGATIVE

Jayant
27/05/24
Assistant Chemist
P.H. Division, Purnea

Kumax
27/05/2024
Chemist
P.H. Div.
Purnea

P.H.
27/5/24
A.E.
P.H. Sub Division, Purnea

S.
06.24
Executive Engineer
P.H. Division, Purnea
Executive Engineer
P.H. Division, P.